

# Mass Transfer Efficiency of a Packed Bed Utilizing the Fractal Distributor

## Report

Presented to:

Vadim Kochergin  
Amalgamated Research, Inc.  
P.O. Box 228  
Twin Falls, Idaho 83303-0228  
208/735-5400  
208/733-8604 (fax)

by

A. Frank Seibert, J. Christopher Lewis and James R. Fair

Separations Research Program  
Center for Energy and Environmental Resources  
The University of Texas at Austin

December 18, 2002

## CONTENTS

	Page
LIST OF TABLES	<i>iii</i>
LIST OF FIGURES	<i>iv</i>
LIST OF APPENDICES	<i>v</i>
BACKGROUND	1
EXPERIMENTAL EQUIPMENT	1
MASS TRANSFER RUN PROCEDURE	2
EXPERIMENTAL RESULTS	5
ANALYSIS OF RESULTS	13
CONCLUSIONS	20
APPENDIX	21

## **LIST OF TABLES**

	<b>Page</b>
Table 1. Liquid Distributor Capacity and Specifications	2
Table 2. Physical Properties of Air/Carbon Dioxide/Caustic System	6

## LIST OF FIGURES

	Page
Figure 1. Mass Transfer Column Configuration	4
Figure 2a. Photograph of the Standard SRP Orifice Distributor ( $40 \text{ pts}/\text{ft}^2$ )	6
Figure 2b. Photograph of the High Capacity Trough Drip Tube Distributor ( $13.5 \text{ pts}/\text{ft}^2$ )	6
Figure 2c. Photograph of the Fractal I Distributor ( $10 \text{ pts}/\text{ft}^2$ )	7
Figure 2d. Photograph of the Fractal II Distributor ( $40 \text{ pts}/\text{ft}^2$ )	7
Figure 3. Mass Transfer Efficiency of the Standard SRP Orifice Distributor ( $40 \text{ pts}/\text{ft}^2$ )	9
Figure 4. Mass Transfer Efficiency of the High Capacity Trough Drip Tube Distributor ( $13.5 \text{ pts}/\text{ft}^2$ )	10
Figure 5. Mass Transfer Efficiency of the Fractal I Distributor ( $10 \text{ pts}/\text{ft}^2$ )	11
Figure 6. Mass Transfer Efficiency of the Fractal II Distributor ( $40 \text{ pts}/\text{ft}^2$ )	12
Figure 7. Comparison of Distributors at an f-factor = $0.52 \text{ ft/s (lb/ft}^3)^{0.5}$	14
Figure 8. Comparison of Distributors at an f-factor = $0.86 \text{ ft/s (lb/ft}^3)^{0.5}$	15
Figure 9. Comparison of Distributors at an f-factor = $1.29 \text{ ft/s (lb/ft}^3)^{0.5}$	16
Figure 10. Comparison of Distributors at a Constant Pressure Drop = $0.75 \text{ in H}_2\text{O}/\text{ft}$	17
Figure 11. Comparison of Distributors at a Liquid Rate of $5 \text{ gpm/ft}^2$	18
Figure 12. Comparison of Distributors at a Liquid Rate of $10 \text{ gpm/ft}^2$	19

## LIST OF APPENDICES

	Page
Appendix A.1.1    Mass Transfer Data for the Standard SRP Orifice Distributor (40 pts/ft <sup>2</sup> ), f-factor = 0.52 ft/s (lb/ft <sup>3</sup> ) <sup>0.5</sup>	23
Appendix A.1.2    Mass Transfer Data for the Standard SRP Orifice Distributor (40 pts/ft <sup>2</sup> ), f-factor = 0.87 ft/s (lb/ft <sup>3</sup> ) <sup>0.5</sup>	24
Appendix A.1.3    Mass Transfer Data for the Standard SRP Orifice Distributor (40 pts/ft <sup>2</sup> ), f-factor = 1.29 ft/s (lb/ft <sup>3</sup> ) <sup>0.5</sup>	25
Appendix A.1.4    Mass Transfer Data for the Standard SRP Orifice Distributor (40 pts/ft <sup>2</sup> ), ΔP/Z <sub>p</sub> = 0.75 in H <sub>2</sub> O/ft	26
Appendix A.2.1    Mass Transfer Data for the High Capacity Trough Drip Tube Distributor (13.5 pts/ft <sup>2</sup> ), f-factor = 0.52 ft/s (lb/ft <sup>3</sup> ) <sup>0.5</sup>	27
Appendix A.2.2    Mass Transfer Data for the High Capacity Trough Drip Tube Distributor (13.5 pts/ft <sup>2</sup> ), f-factor = 0.87 ft/s (lb/ft <sup>3</sup> ) <sup>0.5</sup>	28
Appendix A.2.3    Mass Transfer Data for the High Capacity Trough Drip Tube Distributor (13.5 pts/ft <sup>2</sup> ), f-factor = 1.29 ft/s (lb/ft <sup>3</sup> ) <sup>0.5</sup>	29
Appendix A.2.4    Mass Transfer Data for the High Capacity Trough Drip Tube Distributor (13.5 pts/ft <sup>2</sup> ), ΔP/Z <sub>p</sub> = 0.75 in H <sub>2</sub> O/ft	30
Appendix A.3.1    Mass Transfer Data for the Fractal I Distributor (10 pts/ft <sup>2</sup> ), f-factor = 0.52 ft/s (lb/ft <sup>3</sup> ) <sup>0.5</sup>	31
Appendix A.3.2    Mass Transfer Data for the Fractal I Distributor (10 pts/ft <sup>2</sup> ), f-factor = 0.87 ft/s (lb/ft <sup>3</sup> ) <sup>0.5</sup>	32
Appendix A.3.3    Mass Transfer Data for the Fractal I Distributor (10 pts/ft <sup>2</sup> ), f-factor = 1.29 ft/s (lb/ft <sup>3</sup> ) <sup>0.5</sup>	33
Appendix A.3.4    Mass Transfer Data for the Fractal I Distributor (10 pts/ft <sup>2</sup> ), ΔP/Z <sub>p</sub> = 0.75 in H <sub>2</sub> O/ft	34

Appendix A.4.1	Mass Transfer Data for the Fractal II Distributor (40 pts/ft <sup>2</sup> ), f-factor = 0.52 ft/s (lb/ft <sup>3</sup> ) <sup>0.5</sup>	35
Appendix A.4.2	Mass Transfer Data for the Fractal II Distributor (40 pts/ft <sup>2</sup> ), f-factor = 0.87 ft/s (lb/ft <sup>3</sup> ) <sup>0.5</sup>	36
Appendix A.4.3	Mass Transfer Data for the Fractal II Distributor (40 pts/ft <sup>2</sup> ), f-factor = 1.29 ft/s (lb/ft <sup>3</sup> ) <sup>0.5</sup>	37
Appendix A.4.4	Mass Transfer Data for the Fractal II Distributor (40 pts/ft <sup>2</sup> ), $\Delta P/Z_p = 0.75$ in H <sub>2</sub> O/ft	38
Appendix A.5	Procedure for Calculating Mass Transfer Area	39

# Mass Transfer Efficiency of a Packed Bed Utilizing the Fractal Distributor

December 18, 2002

*A. Frank Seibert, J. Christopher Lewis and James R. Fair*

## BACKGROUND

The Separations Research Program (SRP) conducted a series of carbon dioxide/caustic absorption experiments tests to determine the mass transfer characteristics of a Montz B1-500 packed bed using four different liquid distributors:

- 1) Standard SRP Orifice Distributor (40 pts/ft<sup>2</sup>)
- 2) High Capacity Trough Drip Tube Distributor (13.5 pts/ft<sup>2</sup>)
- 3) Fractal I Distributor (10 pts/ft<sup>2</sup>)
- 4) Fractal II Distributor (40 pts/ft<sup>2</sup>)

Algamated Research, Inc. provided the Fractal distributors that were fabricated from plastic materials. The Separations Research Program provided the orifice and trough drip tube distributors. The primary objective of the study was to determine the effect of the liquid distributor type on packing mass transfer. The Montz B1-500 structured packing was selected because of its large available surface area which is thought to be difficult to wet completely with conventional liquid distributors. Also, the higher surface area should enable better discrimination among the effects of the different distributors. In these tests, only distributor was varied.

## Experimental Equipment

The hydraulic and mass transfer performance of the packings was measured using a 16.8-in I.D. PVC air/water column connected to a 350 gallon capacity sump. The hydraulic system setup is shown in Figure 1. The packing elements were loaded into the column by lowering the elements onto a corrugated-type support plate for structured packing. The packed height was 118 inches. Inlet and outlet temperatures were measured with type-K thermocouples. The water flow rate was measured using an orifice plate and differential pressure transmitter. Water was supplied to the top of the column from the re-circulation tank via a centrifugal pump capable of discharging 150 gpm. Water flow was regulated with an automatic control valve. A 40 HP blower with variable speed motor drive supplied air to the column.

Pressure drop data were measured using a commercially available differential pressure cell (DPC) calibrated for 0-30 inches of water. Both legs of the cells were periodically purged of any entrained liquid, to insure accuracy.

Mass transfer data were calculated by comparing the carbon dioxide ( $\text{CO}_2$ ) concentration in ambient air entering the column with the  $\text{CO}_2$  concentration in the exit air, after scrubbing with a sodium hydroxide solution. The ambient  $\text{CO}_2$  concentration generally ranged from 360 to 380 ppm. Carbon dioxide concentration levels were measured with a Horiba VIA-510 analyzer. The Horiba analyzer provided four calibration ranges:

- 0-100 ppm
- 0-200 ppm
- 0-500 ppm
- 0-1000 ppm.

The 0-500 ppm range was utilized in these experiments. The analyzer was calibrated before the start of each run. It was equipped to provide a 4-20 ma signal to our Fisher-Rosemount Delta-V process computer. This feature allowed for online  $\text{CO}_2$  monitoring and calculation of the mass transfer efficiency. The diameter and length of the sample piping was optimized to minimize residence time.

Four liquid distributors are utilized, to ensure proper initial liquid distribution. See Table 1.

**Table 1. Liquid Distributor Capacity and Specifications**

Type	<u>pts</u> <u>ft<sup>2</sup></u>	Drip Points	hole diameter, in	Min Liquid Flux, gpm/ft <sup>2</sup>	Max
SRP Orifice	40.0	60	0.161	1	20
Trough Drip Tube	13.5	21	0.22	1	31.3
Fractal I	10	15	0.245	1	30
Fractal II	40	60	0.113	1	30

## MASS TRANSFER RUN PROCEDURE

Approximately 300 gallons of 0.1 N NaOH solution are charged to the sump tank located below the packed column. The contents of the sump are then recycled through a pump bypass line. Care is taken to minimize contact with the stagnant air. During the mass transfer process, the  $\text{CO}_2$  in air reacts with the sodium hydroxide to form sodium carbonate ( $\text{Na}_2\text{CO}_3$ ):




A Horiba VIA-510 CO<sub>2</sub> analyzer monitors carbon dioxide concentration in the inlet and outlet air streams. This analyzer is checked at the start of each run with calibration gas (459 ppm CO<sub>2</sub>) fed from a pressurized cylinder. The analyzer's baseline or "zero" is checked using pure nitrogen fed from a pressurized container.

After the instrument calibration, the initial concentration of CO<sub>2</sub> in ambient air is measured. Next, the sample piping is configured to analyze the effluent stream. The concentration of CO<sub>2</sub> is measured online.

For the present study, tests were performed at three air rates (180 ACFM, 300, and 450 ACFM) with liquid rates varying in sequence at 2.5, 5, 15, and 20 gpm/ft<sup>2</sup>. We were unable to operate with higher rates because of the hydraulic limitations associated with the 500 m<sup>2</sup>/m<sup>3</sup> packing. The air rate was fixed and the liquid rate was varied. In addition, runs were carried out at a constant pressure drop of 0.75 in H<sub>2</sub>O/ft for the liquid rates 2.5, 5, 10, 15, and 20 gpm/ft<sup>2</sup>. In the constant pressure drop runs, the liquid rate was fixed and the air rate was changed to provide a pressure drop of 0.75 in H<sub>2</sub>O/ft. A process flow diagram is shown in Figure 1B.

A de-entraining device (Trutna Tray) was added to prevent accidental release of the sodium hydroxide solution. However, special care was taken to avoid a need for de-entraining. Also, the effluent gas sample was taken upstream of the Trutna tray; thus that device did not contribute to the mass transfer measurements. Steady state was achieved when the CO<sub>2</sub> concentration reached a constant value (stopped rising or falling). In general, steady state was achieved within 10-15 minutes of a set point change.

Figure 1. Mass Transfer Configuration



jcl08152001

Figure 1. Mass Transfer Test Configuration

## EXPERIMENTAL RESULTS

Tests were carried out at atmospheric pressure (14.7 psia) to evaluate the packed column mass transfer performance using four liquid distributors with the air/carbon dioxide/caustic test system. The mass transfer performance of each distributor is shown in Figures 3-6. The performance is shown to depend on the gas f-factor and liquid velocity (gpm/ft<sup>2</sup>).

The gas f-factor is defined below.

$$f - \text{factor} = U_s \sqrt{\rho_v}$$

where  $U_s$  = superficial gas velocity, ft/sec


$\rho_g$  = vapor density, lb/ft<sup>3</sup>

The tests were generally carried out at a range of velocities (1 – 20 gpm/ft<sup>2</sup>).

The physical properties of the air/carbon dioxide/caustic system are given in Table 1.

**Table 2. Physical Properties of the Air/CO<sub>2</sub>/Caustic System**


Pressure (psia)	14.7
Liquid density, lb/ft <sup>3</sup>	62.4
Liquid viscosity, cP	0.89
Vapor density, lb/ft <sup>3</sup>	0.073
Vapor viscosity, cP	0.018
Surface tension, dynes/cm	72
Average Temperature, °F	85



(a)

(b)

Figures 2a and b. Photographs of the Standard SRP Orifice Pipe Distributor with 40 pts/ $\text{ft}^2$  (a) and the High Capacity Trough Drip Tube Distributor with 13.5 pts/ $\text{ft}^2$  (b).



Figures 2c and d. Photographs of the Fractal I 10 pts/ $\text{ft}^2$  Distributor (c) and Fractal II 40 pts/ $\text{ft}^2$  Distributor (d).

Mass transfer efficiencies were measured at a range of liquid rates (1 - 20 gpm/ft<sup>2</sup>) and three air rates (180, 300 and 450 scfm). The upper range of the liquid rate was limited by the reduced capacity with the high surface area of the B1-500 packing. In addition, the mass transfer efficiencies at a range of liquid rates were measured at 0.75 in H<sub>2</sub>O/ft of packing. The mass transfer efficiencies, shown as effective mass transfer area, are provided in Figures 3-6. The mass transfer efficiency was calculated from the following equations:

$$NTU_{og} = \ln\left(\frac{Y_{CO_2,in}}{Y_{CO_2,out}}\right)$$

where:  $Y_{CO_2,in}$  = carbon dioxide concentration in the inlet air, ppm  
 $Y_{CO_2,out}$  = carbon dioxide concentration in the outlet air, ppm

$$HTU_{og} = \frac{Z_p}{NTU_{og}}$$

where:  $Z_p$  = packed height, ft


$$HTU_{og} = \frac{U_g}{\overline{K}_{og} a} \quad \text{where } \overline{K}_{og} a \text{ lumps together chemical reaction, mass transfer coefficient, area and concentration.}$$

$U_g$  = Superficial velocity of the gas, ft/s


$$\overline{K}_{og} a = \frac{U_g}{HTU_{og}} = \frac{U_g}{(Z_p / NTU_{og})}$$

The effective mass transfer area was estimated using the method given in Appendix A.5.


**Figure 3. Mass Transfer Efficiency of the Standard SRP Orifice Distributor (40 pts/ft<sup>2</sup>)**




**Figure 4. Mass Transfer Efficiency of the High Capacity Trough Drip Tube Distributor (13.5 pts/ft<sup>2</sup>)**



**Figure 5. Mass Transfer Efficiency of the Fractal I Distributor  
(10 pts/ft<sup>2</sup>)**



**Figure 6. Mass Transfer Efficiency of the Fractal II Distributor  
(40 pts/ft<sup>2</sup>)**




## **ANALYSIS OF RESULTS**


The mass transfer efficiency, expressed as the effective mass transfer area per available packing surface area, was observed to depend strongly on the gas f-factor. The increased gas velocity appears to assist in the liquid spreading and distribution. The efficiency was slightly dependent on liquid rate. In general for a given distribution point density, the Fractal distributors outperformed the orifice and trough drip tube distributors by approximately 20-30%. The performance of distributors are compared in Figures 7-12. The standard SRP orifice and high capacity trough drip tube distributors performed similarly.

The increasing slope of the fractional coverage with liquid rates indicates that additional improvements in distribution are possible.


**Figure 7. Comparison of Distributors at an f-factor = 0.52 ft/s ( $\text{lb/ft}^3$ )<sup>0.5</sup>**



**Figure 8. Comparison of Distributors at an f-factor = 0.86 ft/s ( $\text{lb}/\text{ft}^3$ )<sup>0.5</sup>**



**Figure 9. Comparison of Distributors at an f-factor = 1.29 ft/s ( $\text{lb}/\text{ft}^3\right)^{0.5}$**



**Figure 10. Comparison of Distributors at a Constant  $\Delta P = 0.75$  in  $H_2O/ft$**





Figure 11. Effect of Distributor Type and f-factor on the Mass Transfer Efficiency

Air/CO<sub>2</sub>/Caustic

Caustic Rate = 5 gpm/ft<sup>2</sup>




\* Some points are interpolated

Figure 12. Effect of Distributor Type and f-factor on the Mass Transfer Efficiency

Air/CO<sub>2</sub>/Caustic

Caustic Rate = 10 gpm/ft<sup>2</sup>



\* Some points are interpolated

## **CONCLUSIONS**

For the tests described in this report, the mass transfer efficiency of the packings was found to depend on the type and geometry of the liquid distributor. The 40-point Fractal distributor was found to be superior to the others and was significantly better than the orifice distributor with the same (40) pour points. Notably , the 40-point Fractal distributor provided 6 to 20% greater effective surface than its 10-point counterpart, depending on gas and liquid flow rates.

The comparisons are given in terms of effective wetted surface. Since the same chemical system was being used for all tests, the enhancement of effective area should translate to an enhancement of the volumetric mass transfer coefficient ( $K_{og}a$ ) and thus of the overall rate of mass transfer.

The data presented here are for unidirectional mass transfer, as in absorbers or strippers. Additional tests should be made under distillation conditions, where equimolar counter-diffusion prevails. It is quite possible that the same relative effects of the distributor will be observed.

## **ACKNOWLEDGEMENTS**

The authors gratefully acknowledge SRP technicians Steve Briggs and Robert Montgomery for their invaluable assistance during the study. The authors also acknowledge Ian Wilson, UT Chemical Engineering graduate student, for providing the detailed sodium hydroxide analysis for each run. We also acknowledge the assistance and consultation of Professor Gary Rochelle in establishing the techniques for the measurement of effective mass transfer area.

## LIST OF APPENDICES

	Page
Appendix A.1.1 Mass Transfer Data for the Standard SRP Orifice Distributor (40 pts/ft <sup>2</sup> ), f-factor = 0.52 ft/s (lb/ft <sup>3</sup> ) <sup>0.5</sup>	23
Appendix A.1.2 Mass Transfer Data for the Standard SRP Orifice Distributor (40 pts/ft <sup>2</sup> ), f-factor = 0.87 ft/s (lb/ft <sup>3</sup> ) <sup>0.5</sup>	24
Appendix A.1.3 Mass Transfer Data for the Standard SRP Orifice Distributor (40 pts/ft <sup>2</sup> ), f-factor = 1.29 ft/s (lb/ft <sup>3</sup> ) <sup>0.5</sup>	25
Appendix A.1.4 Mass Transfer Data for the Standard SRP Orifice Distributor (40 pts/ft <sup>2</sup> ), ΔP/Z <sub>p</sub> = 0.75 in H <sub>2</sub> O/ft	26
Appendix A.2.1 Mass Transfer Data for the High Capacity Trough Drip Tube Distributor (13.5 pts/ft <sup>2</sup> ), f-factor = 0.52 ft/s (lb/ft <sup>3</sup> ) <sup>0.5</sup>	27
Appendix A.2.2 Mass Transfer Data for the High Capacity Trough Drip Tube Distributor (13.5 pts/ft <sup>2</sup> ), f-factor = 0.87 ft/s (lb/ft <sup>3</sup> ) <sup>0.5</sup>	28
Appendix A.2.3 Mass Transfer Data for the High Capacity Trough Drip Tube Distributor (13.5 pts/ft <sup>2</sup> ), f-factor = 1.29 ft/s (lb/ft <sup>3</sup> ) <sup>0.5</sup>	29
Appendix A.2.4 Mass Transfer Data for the High Capacity Trough Drip Tube Distributor (13.5 pts/ft <sup>2</sup> ), ΔP/Z <sub>p</sub> = 0.75 in H <sub>2</sub> O/ft	30
Appendix A.3.1 Mass Transfer Data for the Fractal I Distributor (10 pts/ft <sup>2</sup> ), f-factor = 0.52 ft/s (lb/ft <sup>3</sup> ) <sup>0.5</sup>	31
Appendix A.3.2 Mass Transfer Data for the Fractal I Distributor (10 pts/ft <sup>2</sup> ), f-factor = 0.87 ft/s (lb/ft <sup>3</sup> ) <sup>0.5</sup>	32
Appendix A.3.3 Mass Transfer Data for the Fractal I Distributor (10 pts/ft <sup>2</sup> ), f-factor = 1.29 ft/s (lb/ft <sup>3</sup> ) <sup>0.5</sup>	33
Appendix A.3.4 Mass Transfer Data for the Fractal I Distributor (10 pts/ft <sup>2</sup> ), ΔP/Z <sub>p</sub> = 0.75 in H <sub>2</sub> O/ft	34
Appendix A.4.1 Mass Transfer Data for the Fractal II Distributor (40 pts/ft <sup>2</sup> ), f-factor = 0.52 ft/s (lb/ft <sup>3</sup> ) <sup>0.5</sup>	35

<b>Appendix A.4.2</b>	<b>Mass Transfer Data for the Fractal II Distributor (40 pts/ft<sup>2</sup>), f-factor = 0.87 ft/s (lb/ft<sup>3</sup>)<sup>0.5</sup></b>	<b>36</b>
<b>Appendix A.4.3</b>	<b>Mass Transfer Data for the Fractal II Distributor (40 pts/ft<sup>2</sup>), f-factor = 1.29 ft/s (lb/ft<sup>3</sup>)<sup>0.5</sup></b>	<b>37</b>
<b>Appendix A.4.4</b>	<b>Mass Transfer Data for the Fractal II Distributor (40 pts/ft<sup>2</sup>), <math>\Delta P/Z_p = 0.75</math> in H<sub>2</sub>O/ft</b>	<b>38</b>
<b>Appendix A.5</b>	<b>Procedure for Calculating Mass Transfer Area</b>	<b>39</b>

### APPENDIX A.1.1. Mass Transfer Data for the Standard SRP Orifice Distributor (40psi/ft<sup>2</sup>). f-factor = 0.52 ft/s (lb/ft<sup>3</sup>)<sup>0.5</sup>

#### The Separations Research Program

packed height	1.18 inches	Packing:	Moniz B1-500
f-factor	0.52 ( $\frac{f}{f_n} \cdot k^{\frac{1}{n}}$ ) <sup>0.5</sup>		
C <sub>Na</sub>	0.0900 N		
Tank Volume	30.00 gallons		
H <sub>w</sub>	0.034 g/mole/L-atm		
surface area/volume *	500 $m^2/m^3$		

\* approximate

#### PROCESS DATA

run #	time	Water Flow FTgal	Air Flow FTgal	Pressure Drop FTD <sub>1301</sub>	Air Press PT900	Air In 1500	Water In T <sub>101</sub>	Air Out T <sub>102</sub>	CO <sub>2</sub> , H <sub>2</sub> O	
									(in H <sub>2</sub> O)	(PSIG)
1	10/30/02 13:40	15.40	179.7	2.01	0.03	97.08	94.92	100.42	386	84
2	10/30/02 13:47	11.47	180.1	1.31	0.02	96.82	94.51	100.11	386	86
3	10/30/02 13:54	7.70	180.0	1.08	0.02	96.31	94.14	100.71	386	89
4	10/30/02 14:06	3.80	179.5	0.88	0.02	95.60	93.48	102.36	386	97
5	10/30/02 14:22	1.94	180.9	0.70	0.01	94.70	92.65	101.55	386	107
6	10/30/02 14:38	0.84	160.0	0.65	0.01	93.47	91.78	100.82	386	113

#### RESULTS

run	K <sub>GA</sub>	NTU <sub>G</sub>	NTU <sub>G</sub>	K <sub>G</sub>	Effective Area in <sup>2</sup> /ft <sup>2</sup>	Effective Area ft <sup>2</sup> /ft <sup>2</sup>	Fractional area $\Phi$	Hydraulic Calculations		
								in	in <sup>2</sup> /ft <sup>2</sup>	ft <sup>2</sup> /ft <sup>2</sup>
1	0.302	1.527	6.438	6.62E-05	176.65	53.84	0.35	19.98	0.52	0.205
2	0.298	1.506	6.530	6.73E-05	171.70	52.33	0.34	14.88	0.52	0.133
3	0.290	1.463	6.722	6.63E-05	169.15	51.56	0.34	9.99	0.52	0.110
4	0.273	1.380	7.123	6.44E-05	163.26	49.76	0.33	4.93	0.52	0.089
5	0.256	1.284	7.658	6.26E-05	157.64	48.05	0.32	2.52	0.52	0.071
6	0.244	1.232	7.980	6.05E-05	155.98	47.54	0.31	1.08	0.52	0.066

#### HYDRAULIC CALCULATIONS

water velocity $\frac{H^{\frac{1}{2}}}{f_D}$	f-factor $\left(\frac{f}{f_n} \cdot k^{\frac{1}{n}}$	Pressure Drop $\frac{H^{\frac{1}{2}}}{f_D}$ packing
19.98	0.52	0.205
14.88	0.52	0.133
9.99	0.52	0.110
4.93	0.52	0.089
2.52	0.52	0.071
1.08	0.52	0.066

#### MASS TRANSFER CALCULATIONS

Molar Concentration	Ionic Concentration	Ionic Strength	Henry's Law Constant	Viscosity	Diffusivity	Rate Constant	$k_{\text{L}}$
N	Na <sup>+</sup>	OH <sup>-</sup>	CO <sub>2</sub>	CP	m <sup>2</sup> /s		
0.0900	0.0900	0.0900	0.0000	0.0900	30.3910	0.9447	2.56E-09
0.0890	0.0890	0.0890	0.0010	0.0915	29.4118	0.9443	2.55E-09
0.0880	0.0880	0.0880	0.0020	0.0930	29.4118	0.9439	2.54E-09
0.0860	0.0860	0.0860	0.0040	0.0960	29.4118	0.9431	2.51E-09
0.0850	0.0850	0.0850	0.0050	0.0975	29.4118	0.9427	2.49E-09
0.0830	0.0830	0.0830	0.0070	0.1005	29.4118	0.9419	2.46E-09

Values for molar concentration were measured before and after each gas rate by titration and TIC

**APPENDIX A.1.2. Mass Transfer Data for the Standard SRP Orifice Distributor ( $40 \text{ psi}/\text{ft}^2$ ). f-factor = 0.86 ft/s ( $\text{lb}/\text{ft}^3$ ) $^{0.5}$**

The Separations Research Program

	packed height	inches $(V_h P_h)^{0.5}$	Packing	Moniz B-1500
f-factor	0.86			
C <sub>total</sub>	0.0800	N		
Tank Volume	300.00	gallons		
H <sub>w</sub>	0.034	gmole/l-atm		
surface area/volume *	530	$\text{m}^2/\text{m}^3$		

\* approximate

**PROCESS DATA**

run #	line	Water Flow FT001	Air Flow F1006	Pressure Drop PDT931	Air Press PT1000	A <sub>eff</sub> in	Water in FT011	Air O <sub>2</sub> at 190°C	O <sub>2</sub> Out
1	10/30/02 14:52	13.49	300.1	5.68	0.09	95.52	90.69	99.68	393
2	10/30/02 15:02	11.66	299.6	3.20	0.05	95.05	90.13	98.57	393
3	10/30/02 15:10	9.54	301.2	2.01	0.04	93.97	89.60	96.91	393
4	10/30/02 15:17	5.77	300.2	1.50	0.03	93.09	89.21	96.64	393
5	10/30/02 15:26	1.91	300.3	1.28	0.02	91.96	88.81	96.61	393
6	10/30/02 14:35	0.80	178.8	0.66	0.01	93.75	91.97	101.07	386

**RESULTS**

run	K <sub>cA</sub>	NTU <sub>cA</sub>	NTU <sub>On</sub>	K <sub>'cA</sub>	Effective Area	Effective Area	Fractional area	
1	0.371	1.122	8.762	5.61E-05	256.24	78.10	0.51	
2	0.350	1.062	9.258	5.72E-05	237.58	72.42	0.48	
3	0.347	1.047	9.391	5.57E-05	242.55	73.93	0.49	
4	0.336	1.016	9.680	5.48E-05	238.62	72.73	0.48	
5	0.315	0.952	10.326	5.32E-05	230.69	70.31	0.46	
6	0.243	1.237	7.948	5.74E-05	163.91	49.96	0.33	

**HYDRAULIC CALCULATIONS**

	water velocity	f-factor	Pressure drop
	$\frac{\rho g V_w^2}{4 f D_p}$	$(\frac{f}{4})^{\frac{1}{2}}$	$\frac{\rho g V_w^2}{4 D_p}$

**MASS TRANSFER CALCULATIONS**

Molar Concentration	Ionic Concentration	Ionic Strength	Henry's Law Constant	Viscosity	Diffusivity	Rate Constant	$k_{trate}$
N	Na <sup>+</sup>	OH <sup>-</sup>	CO <sub>3</sub> <sup>2-</sup>	CO <sub>2</sub>	$\frac{1}{1 - 4.77 \frac{P_{CO_2}}{P_{CO_2,air}}}$	$\frac{1}{1 - 4.77 \frac{P_{CO_2}}{P_{CO_2,air}}}$	$\frac{1}{1 - 4.77 \frac{P_{CO_2}}{P_{CO_2,air}}}$
0.0800	0.08	0.0800	0.0000	0.0000	0.0800	30.2659	0.9406
0.0810	0.08	0.0810	-0.0010	-0.0010	0.0785	29.4118	0.9411
0.0790	0.08	0.0790	0.0010	0.0010	0.0815	29.4118	0.9402
0.0760	0.08	0.0760	0.0020	0.0020	0.0830	29.4118	0.9398
0.0750	0.08	0.0750	0.0050	0.0050	0.0875	29.4118	0.9386
0.0740	0.08	0.0740	0.0060	0.0060	0.0890	29.4118	0.9382

**APPENDIX A.1.3. Mass Transfer Data for the Standard SRP Orifice Distributor (40 pts/ft<sup>2</sup>). f-factor = 1.29 ft/s(lb/ft<sup>3</sup>)<sup>0.5</sup>**

**The Separations Research Program**

packed height	118 inches	Packing:	Montz B1-500
f-factor	1.30 $(V_{\text{t}} V_{\text{m}})^{0.5}$		
C <sub>total</sub>	0.0720 N		
Tank Volume	300.00 gallons		
H <sub>w</sub>	0.034 g/mole/L-atm		
surface area/volume *	500 $\text{m}^2/\text{m}^3$		

CONSTANTS	
Henry's Law Constant Calc's	
<i>l</i>	
Na <sup>+</sup>	0.091
OH <sup>-</sup>	0.066
HCO <sub>3</sub> <sup>-</sup>	0.021
CO <sub>3</sub> <sup>2-</sup>	
CO <sub>2</sub>	-0.019

PROCESS DATA		Water Flow FT <sup>3</sup> /hr	Air Flow FT <sup>3</sup> /hr	Pressure Dif P <sub>1</sub> -P <sub>2</sub>	Air Press P <sub>1500</sub>	Air In T <sub>50</sub>	Water In T <sub>60</sub>	Air Out T <sub>90</sub>	CO <sub>2</sub> in
run #	time	KPH	{ACFM}	(in H <sub>2</sub> O)	(PSIG)	(F)	(F)	(F)	(ppm)
1	10/30/02 15:52	5.70	448.3	5.71	0.10	96.29	86.81	94.03	393
2	10/30/02 16:00	3.33	450.9	3.85	0.07	94.98	86.28	92.31	393
3	10/30/02 16:09	1.83	451.8	3.18	0.06	91.92	85.66	91.29	393
4	10/30/02 16:15	0.73	447.8	2.97	0.06	89.84	85.19	87.40	393

HYDRAULIC CALCULATIONS									
RESULTS	K <sub>ca</sub> A	N <sub>TU</sub> Q <sub>0</sub>	H <sub>TU</sub> Q <sub>0</sub>	K <sub>G</sub>	Effective Area	Effective Area	Fractional area	f-factor	Pressure Drop
run	s	ft <sup>2</sup>	ft <sup>3</sup> /min	ft <sup>3</sup> /min	ft <sup>2</sup> /ft <sup>3</sup>	ft <sup>2</sup> /ft <sup>3</sup>	ft <sup>2</sup>	(f)	(f)( $\frac{\rho_1}{\rho_2}$ ) <sup>0.5</sup>
1	0.325	0.658	14.934	4.81E-05	264.62	80.62	0.53	7.40	1.29
2	0.307	0.619	15.884	4.80E-05	251.34	76.61	0.50	4.32	1.30
3	0.277	0.557	17.666	4.68E-05	232.45	70.85	0.46	2.37	1.30
4	0.268	0.544	18.068	4.59E-05	231.42	70.54	0.46	0.95	1.29

MASS TRANSFER CALCULATIONS		Ionic Concentration		Ionic Strength	Henry's Law Constant	Viscosity	Diffusivity	Rate Constant	$\rho_g$
Molar Concentration	Na <sub>3</sub>	OH <sup>-</sup>	HCO <sub>3</sub> <sup>-</sup>	CO <sub>2</sub>	cP	m <sup>2</sup> /s	m <sup>2</sup> /s	10 <sup>-6</sup> mole %	( $\rho_{\text{air}}$ / $\rho_{\text{H}_2\text{O}}$ )
N	0.0720	0.07	0.0720	0.0000	0.0720	30.1974	2.30E-09	12.739	0.03914
0.0700	0.07	0.0700	0.0020	0.0750	29.4118	0.9366	2.28E-09	12.474	0.03927
0.0690	0.07	0.0690	0.0030	0.0765	29.4118	0.9362	2.26E-09	12.163	0.03934
0.0680	0.07	0.0680	0.0040	0.0780	29.4118	0.9357	2.25E-09	11.936	0.03962

**APPENDIX A.1.4. Mass Transfer Data for the Standard SRP Orifice Distributor (40 pts/ft<sup>2</sup>).  $\Delta P/Z_p = 0.75$  in H<sub>2</sub>O/ft.**

The Separations Research Program

		RUN NUMBER
packed height	118 inches ( $^{10} \text{ ft}^2/\text{in}^2$ ) <sup>0.5</sup>	
f-factor	1.22	
C <sub>real</sub>	0.0650	N
Tank Volume	300.00	gallons
H <sub>w</sub>	0.034	g/mole/L atm
surface area/volume *	500.000	m <sup>2</sup> /m <sup>3</sup>

\* approximate

**PROCESS DATA**

	Water Flow Ft <sup>3</sup> /s1	Air Flow Ft <sup>3</sup> /s0	Pressure Diff PDSI <sub>s1</sub>	Air Press PSIG	Air Vol 1000	V <sub>air</sub> at H 1561	Air Out T <sub>902</sub>	CO <sub>2</sub> in	CO <sub>2</sub> Out
run #	time	KPPH (ACFM)	(in H <sub>2</sub> O)	(PSIG)	(F)	(F)	(F)	ppm	ppm
1	10/30/02 16:29	14.50	252.7	7.62	0.12	88.51	84.15	84.37	398
2	10/30/02 16:48	11.605	330.30	7.71	0.12	88.00	83.12	81.64	398
3	10/30/02 16:56	7.70	419.6	7.76	0.13	89.57	82.63	81.12	398
4	10/30/02 17:04	3.82	537.1	7.66	0.13	91.82	82.13	80.57	398
5	10/30/02 17:14	2.00	573.9	7.60	0.14	94.02	81.50	80.18	398

**RESULTS**

	K <sub>GA</sub>	N <sub>TO<sub>2</sub></sub>	N <sub>TO<sub>2</sub></sub>	K <sub>G</sub>	Effective Area m <sup>2</sup> /m <sup>3</sup>	Effective Area ft <sup>2</sup> /ft <sup>3</sup>	fractional area 10 <sup>-3</sup>		
1	0.283	1.019	9.647	4.26E-05	264.97	80.76	0.53	18.81	0.73
2	0.302	0.830	11.840	4.18E-05	289.42	88.22	0.58	15.06	0.96
3	0.296	0.641	15.340	4.09E-05	290.20	88.45	0.58	10.00	1.22
4	0.292	0.495	19.875	3.97E-05	295.74	90.14	0.59	4.95	1.55
5	0.263	0.417	23.596	3.83E-05	275.69	84.03	0.55	2.60	1.66

**HYDRAULIC CALCULATIONS**

	Water velocity $\frac{\text{ft}}{\text{sec}}$	f-factor $(\frac{f}{L})_h(\frac{f}{L})_p$	Pressure Drop $\frac{\text{psi}}{\text{ft}}$
		$= f \cdot C_f \cdot \frac{V^2}{2}$	$= f \cdot C_f \cdot \frac{V^2}{2}$

**MASS TRANSFER CALCULATIONS**

Molar Concentration	Na <sup>+</sup>	OH <sup>-</sup>	Ionic Concentration HCO <sub>3</sub> <sup>-</sup>	CO <sub>2</sub>	Ionic Strength	Henry's Law Constant $\frac{1}{1 + K_p} \frac{P_{CO_2}}{P}$	Viscosity cP	Diffusivity ft <sup>2</sup> /s	Rate Constant $\frac{f_2}{f_1} \frac{C_p}{C_p}$	f <sub>2</sub>
N	0.07	0.0650	0.0000	0.0000	0.0650	30.1201	0.9345	2.21E-09	11.445	0.03984
0.0650	0.07	0.0650	0.0020	0.0680	29.4118	0.9337	2.18E-09	10.974	0.04004	
0.0630	0.07	0.0630	0.0030	0.0695	29.4118	0.9333	2.17E-09	10.758	0.04008	
0.0620	0.07	0.0620	0.0050	0.0725	29.4118	0.9325	2.15E-09	10.543	0.04012	
0.0600	0.07	0.0600	0.0070	0.0755	29.4118	0.9316	2.13E-09	10.273	0.04015	
0.0580	0.07	0.0580								

**APPENDIX A.2.1. Mass Transfer Data for the High Capacity Trough Drip Tube Distributor {13.5 pts/ft<sup>2</sup>}. f-factor = 0.53 ft/s (lb/ft<sup>3</sup>)<sup>0.5</sup>**

**The Separations Research Program**

packed height	118 inches $(\gamma_s)(\rho_w)^{0.5}$	Packing:	Montz B1-500
f-factor	0.53		
C <sub>total</sub>	0.0890	N	
Tank Volume	300.00 gallons		
ft <sub>w</sub>	0.034 gmole/l.-air m <sup>3</sup> /m <sup>3</sup>		
surface area/volume *	580		

\* approximate

**PROCESS DATA**

	Water Flow FT/HO	Air Flow FT/HO	Pressure Drop PDI(30)	Air Press (in H <sub>2</sub> O)	Air In T <sub>40</sub>	Air Out T <sub>92</sub>	CO <sub>2</sub> In	CO <sub>2</sub> Out
run #	l/mc	KP121 (ACFM)	(PSIG)	(F)	(F)	(F)	ppm	ppm
1	10/29/02 9:25	19.25	182.7	4.18	0.07	84.36	82.58	419
2	10/29/02 9:32	15.28	181.1	1.47	0.03	84.16	83.02	419
3	10/29/02 9:39	11.59	183.5	1.11	0.02	84.13	83.35	419
4	10/29/02 9:45	7.69	181.1	0.85	0.02	84.31	83.53	419
5	10/29/02 9:51	3.86	178.5	0.67	0.01	84.48	83.84	419
6	10/29/02 9:58	0.84	180.8	0.50	0.01	84.98	84.12	419

**RESULTS**

run	K <sub>CoA</sub>	NTU <sub>G</sub>	NTU <sub>G</sub>	K <sub>G</sub>	Effective Area in /in <sup>2</sup>	Effective Area in /in <sup>2</sup>	fractional area (p)
1	0.276	1.373	7.162	4.91E-05	224.75	68.50	0.45
2	0.279	1.398	7.035	5.02E-05	221.69	67.57	0.44
3	0.277	1.370	7.176	5.00E-05	220.94	67.34	0.44
4	0.273	1.370	7.179	4.98E-05	219.64	66.95	0.44
5	0.260	1.323	7.432	4.93E-05	210.20	64.07	0.42
6	0.245	1.230	7.996	4.90E-05	198.88	60.62	0.40

**HYDRAULIC CALCULATIONS**

	water velocity	f-factor	Pressure Drop
	$\frac{\text{ft}}{\text{sec}}$	$(\frac{f}{4}) \frac{(W^2)}{g} \frac{h}{L}$	$\frac{\text{ft}^2 \text{lb}^2}{\text{sec}^2 \text{lb}}$
			ft <sup>2</sup> lbf/in <sup>2</sup> packing
			0.425
			0.150
			0.112
			0.087
			0.068
			0.052
			0.040
			0.03986

**MASS TRANSFER CALCULATIONS**

Molar Concentration	Ionic Concentration	Ionic Strength	Henry's Law Constant	Viscosity	Diffusivity	Rate Constant	$\eta_g$
N	Ni <sup>+</sup>	OH <sup>-</sup>	CO <sub>3</sub> <sup>2-</sup>	CP	m <sup>2</sup> s	1/f <sub>max</sub>	1/f <sub>min</sub>
0.0890	0.09	0.0890	0.0000	0.0890	30.3859	2.21E-09	11.334
0.0880	0.09	0.0880	0.0000	0.0905	29.4118	2.20E-09	11.246
0.0880	0.09	0.0880	0.0010	0.0905	29.4118	2.20E-09	11.187
0.0870	0.09	0.0870	0.0020	0.0920	29.4118	2.19E-09	11.147
0.0860	0.09	0.0860	0.0030	0.0935	29.4118	2.19E-09	11.148
0.0850	0.09	0.0850	0.0040	0.0950	29.4118	2.19E-09	11.147

Values for molar concentration were measured before and after each gas rate by titration and TIC

**APPENDIX A.2.2. Mass Transfer Data for the High Capacity Trough Drip Tube Distributor. f-factor = 0.87 ft/s (lb/ft<sup>3</sup>)<sup>0.5</sup>**

**The Separations Research Program**

packed height	118 inches	Packing:	Montz B1-500
f-factor	0.87 ( $\frac{f}{f_s} K_{in}^{0.5}$ )		
C <sub>out</sub>	0.0810 N		
Tank Volume	300.00 gallons		
H <sub>w</sub>	0.034 g/mole/L-atm		
surface area/volume *	500 m <sup>2</sup> /m <sup>3</sup>		

\* approximate

**PROCESS DATA**

Run #	time	Water Flow		Air Flow		Pressure Drop		Air In		Water In		Air Out	
		KPH <sub>t</sub>	(ACFM)	PSI <sub>t</sub>	(in H <sub>2</sub> O)	PSIG <sub>t</sub>	(F)	F <sub>t</sub>	1901	1902	1903	CO <sub>2</sub> In	CO <sub>2</sub> Out
1	10/29/02 10:29	13.50	299.5	3.42	0.06	86.59	82.77	83.57				396	150
2	10/29/02 10:35	11.48	303.4	2.09	0.04	88.35	82.72	83.94				396	151
3	10/29/02 10:41	9.62	302.7	1.57	0.03	87.90	82.64	84.38				396	151
4	10/29/02 10:47	5.83	298.5	1.21	0.03	87.96	82.68	84.38				396	153
5	10/29/02 10:54	1.84	301.3	0.97	0.02	87.93	82.69	85.28				396	158
6	10/29/02 11:01	0.74	300.1	0.93	0.02	88.06	82.63	85.43				396	162

**RESULTS**

run	K <sub>degA</sub> S <sup>-1</sup>	NTU <sub>0.05</sub>	HTU <sub>0.05</sub>	K'g	Effective Area m <sup>2</sup> /in <sup>2</sup>	Effective Area ft <sup>2</sup> /in <sup>2</sup>	fractional area (f)
1	0.319	0.968	10.154	4.55E-05	279.68	85.25	0.56
2	0.322	0.964	10.204	4.66E-05	275.53	83.98	0.55
3	0.320	0.961	10.228	4.62E-05	276.35	84.23	0.55
4	0.311	0.948	10.314	4.59E-05	270.18	82.35	0.54
5	0.304	0.917	10.726	4.56E-05	264.87	80.73	0.53
6	0.296	0.896	10.969	4.56E-05	258.38	78.75	0.52

**HYDRAULIC CALCULATIONS**

water velocity $m^3/m^2 s$	Henry's Law Constant $\frac{f}{f_s} K_{in}^{0.5}$	i-factor $(\frac{f}{f_s})^{0.75}$	Pressure Drop $\frac{\rho g \Delta P}{2}$
17.52	0.87	0.348	
14.89	0.88	0.212	
12.49	0.88	0.180	
7.56	0.86	0.123	
2.39	0.87	0.099	
0.97	0.87	0.094	

**MASS TRANSFER CALCULATIONS**

Molar Concentration	Ionic Strength	Henry's Law Constant	Viscosity	Diffusivity	Rate Constant	$f_g$
N	Na <sup>+</sup>	OH <sup>-</sup>	HCO <sub>3</sub> <sup>-</sup>	CO <sub>2</sub>	CP	$\frac{f}{f_s} K_{in}^{0.5}$
0.0810	0.08	0.0810	0.0000	0.0000	0.0810	30.2970
0.0800	0.08	0.0800	0.0010	0.0010	0.0825	29.4118
0.0790	0.08	0.0790	0.0020	0.0020	0.0840	29.4118
0.0780	0.08	0.0780	0.0030	0.0030	0.0855	29.4118
0.0770	0.08	0.0770	0.0040	0.0040	0.0870	29.4118
0.0770	0.08	0.0770	0.0040	0.0040	0.0870	29.4118

**APPENDIX A.2.3. Mass Transfer Data for the High Capacity Trough Drip Tube Distributor. f-factor = 1.29 ft/s(lbf/ft<sup>3</sup>)<sup>0.5</sup>**

**The Separations Research Program**

packed height	1.18	inches	
f-factor	1.29	( $\frac{A}{f_h} K_{h,i}^{P_{CO_2}}$ ) <sup>0.5</sup>	
C <sub>Na</sub>	0.0690	N	
Tank Volume	300.00	gallons	
H <sub>w</sub>	0.034	gmole/l-atm	
surface area/volume *	500	m <sup>2</sup> /m <sup>3</sup>	

CONSTANTS	
Henry's Law Constant Calc	
	$f_h$
Na <sup>+</sup>	0.091
OH <sup>-</sup>	0.066
HCO <sub>3</sub> <sup>-</sup>	0.021
CO <sub>2</sub>	-0.019

**PROCESS DATA**

run #	time	Water Flow FT901	Air Flow	Pressure Drop	Air Press	Air In	Water In	Air Out	CO <sub>2</sub> in	CO <sub>2</sub> Out
			FT900	PT901	PT900	T901	T902	Ft	ppm	ppm
1	10/29/02 11:37	5.68	450.9	4.50	0.08	96.63	82.52	84.26	391	212
2	10/29/02 11:46	3.84	446.5	3.35	0.07	95.18	82.57	85.21	391	219
3	10/29/02 12:14	1.78	449.2	2.91	0.06	95.62	82.56	88.32	391	230
4	10/29/02 12:08	0.82	450.4	2.65	0.06	94.97	82.60	87.74	391	233

**RESULTS**

run	H <sub>o,g,A</sub>	NTU <sub>o,g</sub>	HTU <sub>o,g</sub>	K <sup>c</sup> <sub>G</sub>	Effective Area	Effective Area	fractional area
1	0.304	0.612	16.061	4.19E-05	288.73	88.00	0.53
2	0.286	0.580	16.952	4.27E-05	266.41	81.20	0.53
3	0.263	0.532	18.471	4.24E-05	245.41	74.80	0.49
4	0.256	0.517	19.005	4.22E-05	240.93	73.43	0.48

**HYDRAULIC CALCULATIONS**

water velocity	f-factor	Pressure Drop
$\frac{\text{ft}^2/\text{min}}{\text{ft}^2}$	$(\frac{f_h}{f_g})^{(P_{CO_2}/P_{air})^{0.5}}$	$\frac{\text{inH}_2\text{O}}{\text{ft}}$

**MASS TRANSFER CALCULATIONS**

Molar Concentration	Na	OH	HCO <sub>3</sub> <sup>-</sup>	CO <sub>2</sub>	Ionic Strength	Henry's Law Constant	Viscosity	Diffusivity	Rate Constant	$\Omega_A$
N	0.0690	0.07	0.0690	0.0000	0.0000	0.0690	30.1642	2.16E-09	10.711	0.03985
	0.0680	0.07	0.0680	0.0010	0.0010	0.0705	29.4118	2.17E-09	10.733	0.03978
	0.0670	0.07	0.0670	0.0020	0.0020	0.0720	29.4118	2.17E-09	10.728	0.03955
	0.0660	0.07	0.0660	0.0030	0.0030	0.0735	29.4118	2.17E-09	10.747	0.03959

**APPENDIX A.2.4. Mass Transfer Data for the High Capacity Trough Drip Tube Distributor.  $\Delta PIZ_p = 0.75$  in  $H_2Oft$ .**

The Separations Research Program

RUN NUMBER 0

packed height	118 inches
f-factor	$(\frac{f}{n})^{10} (\frac{n}{f})^5$
C <sub>base</sub>	0.0580 N
Tank Volume	300.00 gallons
H <sub>w</sub>	0.034 gmol/L-atm
surface area/volume *	500.000 m <sup>2</sup> /m <sup>3</sup>

\* approximate

PROCESS DATA

	Water Flow F1901	Air Flow F1900	Pressure Diff F01591	Air Press P15640	Air in 1600	Vapor in T401	Air Out T502	CO <sub>2</sub> Out ppm
run #	KPHH (ACM)	(in H <sub>2</sub> O)	(PSIG)	(F)	(F)	(F)	(F)	ppm
1	10/29/02 12:56	15.42	294.4	7.77	0.12	99.08	83.75	90.36
2	10/29/02 13:25	11.573	348.72	7.60	0.12	100.69	84.43	92.35
3	10/29/02 13:42	7.72	437.0	7.85	0.13	102.42	84.64	92.78
4	10/29/02 14:00	3.81	535.4	7.66	0.14	105.67	84.63	95.46
5	10/29/02 14:11	1.69	563.0	7.97	0.15	108.39	84.77	96.38

RESULTS

run	K <sub>OA</sub>	NTU <sub>00</sub>	NTU <sub>00</sub>	K' <sub>OA</sub>	Effective Area in <sup>2</sup> /in <sup>2</sup>	Effective Area ft <sup>2</sup> /ft <sup>2</sup>	fractional area	i-factor	Pressure Drop
1	0.307	0.947	10.380	3.99E-05	303.01	92.36	0.61	20.01	0.85
2	0.292	0.762	12.904	4.01E-05	286.48	87.32	0.57	15.02	1.00
3	0.284	0.591	16.625	3.96E-05	282.10	85.99	0.56	10.01	1.25
4	0.274	0.465	21.165	3.80E-05	281.28	85.73	0.56	4.95	1.53
5	0.255	0.397	24.775	3.81E-05	260.30	79.34	0.52	2.45	1.66

HYDRAULIC CALCULATIONS

	water velocity ft <sup>3</sup> /in <sup>2</sup>	i-factor $(V_i)(k_i)^{1/2}$	packing $(V_i)(k_i)^{1/2}$	Pressure Drop
				0.790

MASS TRANSFER CALCULATIONS

Molar Concentration	Ionic Concentration	Henry's Law Constant	Viscosity	Diffusivity	Rate Constant	$\frac{P_g}{P_{g,0}}$
N	Na	OH	CO <sub>2</sub>	CP	$\frac{1}{f_{CO_2}}$	
0.0580	0.06	0.0580	0.0000	0.0580	30.0430	0.9316
0.0540	0.06	0.0540	0.0040	0.0640	29.4116	0.9300
0.0520	0.06	0.0520	0.0060	0.0670	29.4118	0.9292
0.0480	0.06	0.0480	0.0100	0.0730	29.4116	0.9275
0.0480	0.06	0.0480	0.0100	0.0730	29.4118	0.9275

### APPENDIX A.3.1. Mass Transfer Data for the Fractal I Distributor (10 pts/ft<sup>2</sup>). f-factor = 0.52 ft/s (lb/ft<sup>3</sup>)<sup>0.5</sup>

#### The Separations Research Program

packed height	118 inches ( $m_A^{1/3}/h^{1/3}$ ) <sup>0.5</sup>	Packing:	Montz B1-500
f-factor	0.53		
C <sub>0,sys</sub>	0.0910	N	
Tank Volume	300.00 gallons		
H <sub>w</sub>	0.034 g/mole/L-air		
surface area/volume *	500 m <sup>2</sup> /m <sup>3</sup>		
	* approximate		

CONSTANTS		Henry's Law Constant Calc's	
			$f_A$
Na <sup>+</sup>	0.091		
OH <sup>-</sup>	0.066		
HCO <sub>3</sub> <sup>-</sup>	0.021		
CO <sub>2</sub>	-0.019		

PROCESS DATA		Water Flow FT1901	Air Flow FT1000	Pressure Diff. PDI1001	Air Press. PTS01	Air In T <sub>901</sub>	Water In T <sub>901</sub>	Air Out T <sub>902</sub>	CO <sub>2</sub> In ppm	CO <sub>2</sub> Out ppm
run #	time	KPH	(ACFM)	(in H <sub>2</sub> O)	(PSIG)	(F)	(F)	(F)		
1	10/31/02 16:47	15.36	179.7	3.02	0.05	76.67	85.18	76.93	400	105
2	10/31/02 16:53	11.47	179.6	1.55	0.02	75.60	84.65	76.74	400	105
3	10/31/02 17:01	7.72	179.8	1.29	0.02	74.72	84.00	78.12	400	112
4	10/31/02 17:12	3.84	179.1	1.06	0.02	73.97	83.18	77.33	400	123
5	10/31/02 17:19	1.93	183.3	0.92	0.01	73.63	82.65	76.85	400	129
6	10/31/02 17:28	0.78	182.1	0.89	0.01	73.28	82.06	76.59	400	137

RESULTS	K <sub>0,A</sub> S <sup>-1</sup>	NTU <sub>0,0</sub>	HTU <sub>0,0</sub>	K' <sub>0,A</sub> ft <sup>-1</sup>	Effective Area ft <sup>2</sup> /ft <sup>2</sup>	Effective Area ft <sup>2</sup> /ft <sup>2</sup>	Fractional area (f)	HYDRAULIC CALCULATIONS		
								water velocity $W^{\star} \frac{v}{h_p}$	Head Factor $(h_p)^{0.5}/(h_n)^{0.5}$	Pressure Drop in 2' h <sub>p</sub> packing
1	0.265	1.339	7.346	5.14E-05	207.43	63.23	0.41		19.94	0.53
2	0.264	1.336	7.358	5.21E-05	204.32	62.28	0.41		14.88	0.53
3	0.251	1.270	7.745	5.09E-05	199.11	60.69	0.40		10.02	0.53
4	0.232	1.177	8.357	4.95E-05	189.26	57.69	0.38		4.98	0.52
5	0.228	1.132	8.688	4.85E-05	190.30	58.00	0.38		2.50	0.54
6	0.215	1.071	9.184	4.74E-05	182.95	55.76	0.37		1.01	0.53

#### MASS TRANSFER CALCULATIONS

Molar Concentration	Ionic Concentration			Ionic Strength	Henry's Law Constant	Viscosity	Diffusivity	Rate Constant	$R_q$
N	Na <sup>+</sup>	OH <sup>-</sup>	HCO <sub>3</sub> <sup>-</sup>	CO <sub>2</sub>					
0.0910	0.09	0.0910	0.0000	0.0000	0.0910	30.4082	0.9451	2.25E-09	11.932
0.0900	0.09	0.0900	0.0010	0.0010	0.0925	29.4118	0.9447	2.23E-09	11.676
0.0890	0.09	0.0890	0.0020	0.0020	0.0940	29.4118	0.9443	2.21E-09	11.376
0.0880	0.09	0.0880	0.0030	0.0030	0.0955	29.4118	0.9439	2.18E-09	11.003
0.0870	0.09	0.0870	0.0040	0.0040	0.0970	29.4118	0.9435	2.17E-09	10.769
0.0860	0.09	0.0860	0.0050	0.0050	0.0985	29.4118	0.9431	2.15E-09	10.514

Values for molar concentration were measured before and after each gas rate by titration and TIC

**APPENDIX A.3.2. Mass Transfer Data for the Fractal I Distributor (10 pts/ft<sup>2</sup>) . f-factor = 0.86 ft/s (lb/ft<sup>3</sup>)<sup>0.5</sup>**

**The Separations Research Program**

packed height	118	inches	$(\frac{P}{P_0})^{0.5}$
f-factor	0.88	N	
C <sub>total</sub>	0.0840		
Tank Volume	300.00	gallons	
H <sub>w</sub>	0.034	gmole/L-atm	
surface area/volume *	50.0	m <sup>2</sup> /m <sup>3</sup>	
			* approximate

\* approximate

**PROCESS DATA**

run #	time	Water Flow		Air Flow		Pressure Drop		Air In		Air Out			
		KPPH	(ACFM)	(in H <sub>2</sub> O)	(PSI(G))	(F)	(F)	T <sub>901</sub>	T <sub>902</sub>	ppm	ppm	CO <sub>2</sub> in	CO <sub>2</sub> out
1	10/31/02 17:41	13.43	298.0	5.59	0.09	76.17	80.87	75.97	400	144			
2	10/31/02 17:53	11.50	300.3	3.54	0.06	75.37	80.04	75.18	400	152			
3	10/31/02 18:01	9.56	300.5	2.28	0.04	74.20	79.51	74.31	400	158			
4	10/31/02 18:07	5.77	300.4	1.68	0.03	73.36	79.15	73.90	400	166			
5	10/31/02 18:12	1.96	299.9	1.43	0.02	72.76	78.90	73.52	400	173			
6	10/31/02 18:20	0.81	298.1	1.39	0.02	72.12	78.43	72.90	400	181			

run	K <sub>cA</sub>	NTU <sub>DG</sub>	HTU <sub>DG</sub>	K <sub>G</sub>	Effective Area m <sup>2</sup> /m <sup>3</sup>	Effective Area ft <sup>2</sup> /ft <sup>3</sup>	fractional area 1/p	HYDRAULIC CALCULATIONS			
								water velocity ft/min	f-factor $(\frac{f}{\pi D})^{0.5}$	packing e <sub>tp</sub>	Pressure Drop
1	0.335	1.023	9.612	4.40E-05	308.76	94.11	0.62		17.42	0.87	0.568
2	0.320	0.969	10.133	4.35E-05	298.14	90.87	0.60		14.92	0.88	0.360
3	0.307	0.928	10.595	4.29E-05	290.58	88.57	0.58		12.41	0.88	0.231
4	0.291	0.881	11.156	4.22E-05	280.57	85.52	0.56		7.49	0.88	0.171
5	0.277	0.838	11.731	4.19E-05	268.56	81.86	0.54		2.55	0.88	0.146
6	0.260	0.793	12.405	4.08E-05	259.22	79.01	0.52		1.05	0.87	0.141

**MASS TRANSFER CALCULATIONS**

Molar Concentration	Ionic Concentration			Henry's Law Constant 1. atm CO <sub>2</sub>	Viscosity cp	Diffusivity m <sup>2</sup> /s	Rate Constant 1/q m <sup>2</sup> /l <sub>in</sub>
	Na <sup>+</sup>	OH <sup>-</sup>	HCO <sub>3</sub> <sup>-</sup>				
0.0840	0.08	0.0840	0.0000	0.0840	0.9423	2.11E-09	10.013
0.0810	0.08	0.0810	0.0030	0.0885	0.9411	2.09E-09	9.675
0.0810	0.08	0.0810	0.0030	0.0885	0.9411	2.07E-09	9.469
0.0800	0.08	0.0800	0.0040	0.0900	0.9406	2.06E-09	9.330
0.0800	0.08	0.0800	0.0040	0.0900	0.9406	2.05E-09	9.231
0.0780	0.08	0.0780	0.0050	0.0930	0.9398	2.04E-09	9.056

CONSTANTS		Henry's Law Constant Calc's	
		$f_f$	
		Na <sup>+</sup>	
		OH <sup>-</sup>	
		HCO <sub>3</sub> <sup>-</sup>	
		CO <sub>2</sub>	
		CO <sub>2</sub>	

HYDRAULIC CALCULATIONS	
water velocity	f-factor
$\frac{\text{ft}}{\text{min}}$	$(\frac{f}{\pi D})^{0.5}$
in/sec	packing

**APPENDIX A.3.3. Mass Transfer Data for the Fractal I Distributor ( $10 \text{ pts}/\text{ft}^2$ ). f-factor =  $1.29 \text{ ft/s}$  ( $\text{lb}/(\text{ft}^3)$ ) $^{0.5}$**

The Separations Research Program

packed height	118	inches	Packing	Montz B1-500
f-factor	1.31	$(\frac{n}{A})^{(P_e - 1)^{0.5}}$		
C <sub>Na</sub>	0.0760	N		
Tank Volume	300.00	gallons		
H <sub>w</sub>	0.034	gmole/L-atm		
surface area/volume *	500	$\text{m}^2/\text{m}^3$		

COMPOSITIONS	
Henry's Law Constant C <sub>i</sub>	
Na <sup>+</sup>	0.091
OH <sup>-</sup>	0.066
HCO <sub>3</sub> <sup>-</sup>	0.021
CO <sub>2</sub>	-0.019

PROCESS DATA

run #	time	Water Flow	Air Flow	Pressure Drop	Air Press	Air In	Water In	Air Out	CO <sub>2</sub> Out	
		KPPH	(ACFM)	(in H <sub>2</sub> O)	(PSIG)	(F <sub>1</sub> )	(F <sub>2</sub> )			
1	10/31/02 18:32	5.78	448.6	5.54	0.09	77.68	77.42	72.80	400	225
2	10/31/02 18:40	3.77	450.2	3.72	0.07	77.34	76.91	72.37	400	231
3	10/31/02 18:45	1.93	449.7	3.18	0.06	77.02	76.62	72.27	400	236
4	10/31/02 18:58	0.76	449.4	2.96	0.06	76.59	75.90	71.89	400	246

RESULTS

run	K <sub>G,A</sub> S <sup>-1</sup>	NTU <sub>OG</sub>	HTU <sub>OG</sub>	K' <sub>G</sub>	Effective Area in <sup>2</sup> /in <sup>2</sup>	Effective Area ft <sup>2</sup> /ft <sup>2</sup>	fractional area (j)	f-factor	
								in <sup>2</sup> /in <sup>2</sup>	ft <sup>2</sup> /ft <sup>2</sup>
1	0.283	0.573	17.156	3.81E-05	302.40	92.17	0.60	7.50	1.31
2	0.273	0.550	17.868	3.84E-05	289.59	88.27	0.58	4.89	0.563
3	0.261	0.528	18.624	3.80E-05	279.94	85.32	0.56	2.51	0.376
4	0.240	0.485	20.295	3.65E-05	267.48	81.53	0.53	0.99	0.301

HYDRAULIC CALCULATIONS

Water velocity	$\frac{W^2}{2g}$	$\frac{(V_w)^2}{2g}$	$\frac{f \cdot L}{D}$	$\frac{f \cdot L}{D} \cdot \frac{V_w^2}{2g}$	Pressure Drop	
					$\frac{f \cdot L}{D}$	$\frac{V_w^2}{2g}$
					7.50	1.31

MASS TRANSFER CALCULATIONS

Molar Concentration	Ionic Concentration			Ionic Strength	Henry's Law Constant	Viscosity	Diffusivity	Rate Constant	$\frac{f_u}{(1 + f_u)}$
	Na <sup>+</sup>	OH <sup>-</sup>	HCO <sub>3</sub> <sup>-</sup>	CO <sub>2</sub>					
0.0760	0.098	0.0760	0.0000	0.0000	0.0760	0.9390	2.01E-09	6.683	0.04070
0.0750	0.096	0.0750	0.0010	0.0010	0.0775	0.9386	2.00E-09	6.501	0.04074
0.0750	0.098	0.0750	0.0010	0.0010	0.0775	0.9386	1.99E-09	6.398	0.04074
0.0720	0.098	0.0720	0.0040	0.0040	0.0820	0.9374	1.97E-09	6.151	0.04077

**APPENDIX A.3.4. Mass Transfer Data for the Fractal I Distributor (10 psf/ft<sup>2</sup>).  $\Delta P/Z_p = 0.75$  in H<sub>2</sub>O/ft**

The Separations Research Program

packed height	1.8 inches	Packing:	Mantz B1-500
f-factor	1.26 $(I_s/I_n)^{0.5}$		
C <sub>max</sub>	0.0700 N		
Tank Volume	300.00 gallons		
H <sub>w</sub>	0.034 gmole/L·dm <sup>-3</sup>		
surface area/volume *	500.000 m <sup>2</sup> /m <sup>3</sup>		

\* approximate

**PROCESS DATA**

run #	time	KTPH	Water Flow	Air Flow	Pressure Drop	Air Press	Air Out				
			Ft <sup>3</sup> /hr	Ft <sup>3</sup> /hr	PSI	PSIG	(F)	(F)	(F)	ppm	ppm
1	10/31/02 19:17	15.50	266.7	7.32	0.11	75.40	75.01	71.34	400	159	
2	10/31/02 19:25	11.64	336.40	7.67	0.12	77.31	74.78	71.27	400	184	
3	10/31/02 19:35	431.9	6.96	0.11	79.46	74.43	71.22	400	225		
4	10/31/02 19:43	772	538.2	0.13	82.51	74.19	71.24	400	254		
5	10/31/02 19:50	3.79	583.9	7.28	0.13	84.83	73.98	71.20	400	270	

**RESULTS**

run	K <sub>0A</sub>	N <sub>TUOG</sub>	HTU <sub>0A</sub>	K <sub>G</sub>	Effective Area	Effective Area	fractional area
1	0.271	0.922	10.661	3.42E-05	322.82	98.40	0.65
2	0.287	0.774	12.705	3.44E-05	340.19	103.69	0.68
3	0.274	0.577	17.056	3.40E-05	328.62	100.16	0.66
4	0.270	0.455	21.604	3.31E-05	332.96	101.49	0.67
5	0.252	0.393	25.027	3.29E-05	313.72	95.62	0.63

**HYDRAULIC CALCULATIONS**

water velocity	I-factor	Pressure Drop
$\frac{\text{in/sec}}{(I_s)(I_n)^{0.5}}$	$\left(\frac{I_s}{I_n}\right)^{0.5} \frac{1}{\rho g}$	$\frac{\Delta P}{(I_s)(I_n)^{0.5}}$

**MASS TRANSFER CALCULATIONS**

Molar Concentration	Ionic Concentration tot	Ionic Strength	Henry's Law Constant	Viscosity	Diffusivity	Rate Constant
N	Na	OH	CO <sub>3</sub> <sup>-</sup>	CO <sub>2</sub>		
0.0700	0.07	0.0700	0.0000	0.0000	0.0700	30.1753
0.0680	0.07	0.0680	0.0020	0.0020	0.0730	29.4118
0.0680	0.07	0.0680	0.0020	0.0020	0.0730	29.4118
0.0650	0.07	0.0650	0.0050	0.0050	0.0775	29.4118
0.0650	0.07	0.0650	0.0050	0.0050	0.0775	29.4118

**APPENDIX A.4.1. Mass Transfer Data for the Fractal II Distributor ( $40 \text{ pts}/\text{ft}^2$ ).  $f$ -factor =  $0.52 \text{ ft/s}$  ( $\text{lb}/\text{ft}^3$ ) $^{0.5}$**

**The Separations Research Program**

packed height	11.8 inches $(\text{m}, \text{ft})^{0.6}$	Packing:	Montz B1-500
f-factor	0.53		
C <sub>gas,out</sub>	0.1000 N		
Tank Volume	300.00 gallons		
H <sub>w</sub>	0.034 g/mole/L-atm		
surface area/volume *	500 m <sup>2</sup> /m <sup>3</sup>		

\* approximate

**PROCESS DATA**

run #	time	Water Flow	Air Flow <sub>w</sub>	Pressure Dif.	Air Press	Air In	Water in	Air Out	CO <sub>2</sub> in	CO <sub>2</sub> Out
		Ft <sup>3</sup> /hr	Ft <sup>3</sup> /hr	PSI	PSIG	Temp	T <sub>g</sub>	Temp	T <sub>g</sub>	ppm
1	11/4/02 15:36	15.40	179.2	1.90	0.03	62.04	71.49	65.02	390	131
2	11/4/02 15:42	13.47	177.7	1.59	0.02	61.95	71.25	64.97	390	135
3	11/4/02 15:48	11.44	179.4	1.44	0.02	61.90	70.98	64.85	390	137
4	11/4/02 15:54	7.75	180.4	1.26	0.02	61.70	70.70	64.78	390	144
5	11/4/02 16:00	3.63	180.9	1.10	0.02	61.44	70.48	64.63	390	152
6	11/4/02 16:05	0.86	181.3	0.95	0.01	61.28	70.15	64.47	390	158

**RESULTS**

run	K <sub>GA</sub>	NTU <sub>GA</sub>	NTU <sub>CO<sub>2</sub></sub>	K <sub>G</sub>	Effective Area	Effective Area	fractional area	
	s <sup>-1</sup>		ft	m <sup>2</sup> /in <sup>2</sup>	ft <sup>2</sup> /in <sup>2</sup>	m <sup>2</sup> /in <sup>2</sup>	(f)	
1	0.215	1.089	9.029	3.41E-05	260.26	79.33	0.52	
2	0.208	1.064	9.243	3.47E-05	247.50	75.44	0.49	
3	0.207	1.048	9.382	3.43E-05	249.56	76.07	0.50	
4	0.197	0.994	9.691	3.40E-05	239.92	73.13	0.48	
5	0.187	0.940	10.458	3.36E-05	230.52	70.26	0.46	
6	0.180	0.903	10.886	3.33E-05	224.12	68.31	0.45	

**HYDRAULIC CALCULATIONS**

water velocity	Hydraulic Head	Factor	Pressure Drop
$\frac{\text{m}^3/\text{s}}{\text{ft}^2/\text{in}^2}$	$(\frac{\text{ft}}{\text{in}^2})^{0.5}$	$(\frac{\text{ft}}{\text{in}^2})^{0.5}$	$\text{psi}^2/\text{ft}^2/\text{in}^2$

**MASS TRANSFER CALCULATIONS**

Molar Concentration	Ionic Concentration	Ionic Strength	Henry's Law Constant	Viscosity	Diffusivity	Rate Constant	$k_{\text{pH}}$	$\tau_{\text{pH}}$
N	Na <sup>+</sup>	OH <sup>-</sup>	HCO <sub>3</sub> <sup>-</sup>	CO <sub>2</sub>	cP	L <sub>pH</sub> cm <sup>3</sup> /mol	L <sub>pH</sub> mol/s	$\tau_{\text{pH}}$
0.0860	0.09	0.0850	0.0900	0.0000	0.0860	30.3526	0.9431	1.84E-09
0.0850	0.09	0.0850	0.0910	0.0010	0.0875	29.4118	0.9427	1.83E-09
0.0840	0.09	0.0840	0.0920	0.0020	0.0890	29.4118	0.9423	1.83E-09
0.0840	0.09	0.0840	0.0930	0.0030	0.0905	29.4118	0.9419	1.81E-09
0.0830	0.09	0.0830	0.0930	0.0030	0.0905	29.4118	0.9419	1.80E-09

Values for molar concentration were measured before and after each gas rate by titration and TIC

**APPENDIX A.4.2. Mass Transfer Data for the Fractal II Distributor (40 pcf/ft<sup>2</sup>). f-factor = 0.86 ft/s (lb/ft<sup>3</sup>)<sup>0.5</sup>**

The Separations Research Program

packed height	118 inches ( $\frac{1}{\alpha} \lambda^{\frac{1}{n}} h_0^{1-\frac{1}{n}}$ ) <sup>0.5</sup>	Packing	Montz B1-500
f-factor	0.89		
C <sub>real</sub>	0.0640 N		
Tank Volume	300.00 gallons		
H <sub>w</sub>	0.034 g/mole/L-atm		
surface area/volume *	500 m <sup>2</sup> /m <sup>3</sup>		
	* approximate		

\* approximate

PROCESS DATA

run #	time	Water Flow FT <sup>3</sup> /h	Air Flow FT <sup>3</sup> /h	Pressure Drop PDI <sup>3</sup>	Air Press F <sup>1500</sup> (in H <sub>2</sub> O)	Water In 1901 (F)	Water Out T <sub>902</sub> (F)	CO <sub>2</sub> In		CO <sub>2</sub> Out	
								KPPH (ACFM)	(PSIG)	ppm	ppm
1	11/4/02 16.17	13.44	302.3	4.31	0.07	63.81	69.75	64.36	383	175	
2	11/4/02 16.25	11.46	302.2	2.73	0.04	63.49	69.40	64.21	383	179	
3	11/4/02 16.31	9.57	299.4	2.12	0.03	62.67	69.18	64.04	383	184	
4	11/4/02 16.35	5.79	302.0	1.68	0.03	62.57	69.05	63.89	383	191	
5	11/4/02 16.41	1.83	300.5	1.47	0.02	62.13	68.73	63.77	383	199	
6	11/4/02 16.47	0.66	299.0	1.43	0.02	62.00	68.49	63.61	383	201	

RESULTS

run	K <sub>GA</sub> S <sup>-1</sup>	NTU <sub>G</sub>	NTU <sub>G</sub>	K <sub>G</sub>	Effective Area m <sup>2</sup> /ft <sup>2</sup>	Effective Area ft <sup>2</sup> /ft <sup>2</sup>	fractional area η <sub>f</sub>	water velocity in/sec	f-factor $(P_f V_{f,0}^{0.5})^{0.5}$	Pressure Drop in <sup>2</sup> psi/ $f_{packing}$
1	0.261	0.786	12.515	3.19E-05	339.07	103.35	0.68			
2	0.253	0.761	12.916	3.21E-05	325.96	99.35	0.65	17.45	0.90	0.439
3	0.241	0.732	13.426	3.17E-05	314.68	95.92	0.63	14.88	0.89	0.278
4	0.231	0.695	14.141	3.16E-05	302.71	92.27	0.61	12.42	0.89	0.215
5	0.216	0.654	15.028	3.11E-05	287.98	87.78	0.58	7.51	0.89	0.171
6	0.213	0.646	15.224	3.05E-05	288.51	87.94	0.58	2.38	0.89	0.149

HYDRAULIC CALCULATIONS

	water velocity in/sec	f-factor $(P_f V_{f,0}^{0.5})^{0.5}$	Pressure Drop in <sup>2</sup> psi/ $f_{packing}$
	17.45	0.90	0.439

MASS TRANSFER CALCULATIONS

Molar Concentration	Na <sup>+</sup>	OH <sup>-</sup>	HCO <sub>3</sub> <sup>-</sup>	CO <sub>2</sub>	Ionic Strength	Henry's Law Constant L J <sup>0.5</sup> /(RT <sub>0</sub> M <sub>0</sub> )	Viscosity cP	Diffusivity m <sup>2</sup> /sec	Rate Constant 1/q 1/f <sub>transfer</sub> s <sup>-1</sup>	Rate Constant m <sup>2</sup> /sec
N	0.0830	0.08	0.0830	0.0000	0.0830	30.3192	0.9419	1.79E-09	6.285	0.04136
0.0810	0.08	0.0810	0.0020	0.0020	0.0860	29.4118	0.9411	1.78E-09	6.192	0.04137
0.0800	0.08	0.0800	0.0030	0.0030	0.0875	29.4118	0.9406	1.78E-09	6.194	0.04138
0.0800	0.08	0.0800	0.0040	0.0040	0.0875	29.4118	0.9405	1.77E-09	6.098	0.04140
0.0790	0.08	0.0790	0.0050	0.0050	0.0920	29.4118	0.9402	1.76E-09	6.015	0.04141
0.0770	0.08	0.0770			0.0920	29.4118	0.9394	1.76E-09	5.995	0.04142

**APPENDIX A.4.3. Mass Transfer Data for the Fractal II Distributor (40 pts/ft<sup>2</sup>). f-factor = 1.29 ft/s (lb/ft<sup>3</sup>)<sup>0.5</sup>**

The Separations Research Program

Packed height	118 inches	Packing:	Montz B1-500
f-factor	1.33 $(V_a)^{0.5}$		
C <sub>total</sub>	0.0560 N		
Tank Volume	300.00 gallons		
H <sub>w</sub>	0.034 g/mol-L-atm		
surface area/volume *	580 m <sup>2</sup> /m <sup>3</sup>		

PROCESS DATA

run #	time	KPHH	(ACFM)	Water Flow	Air Flow	Pressure Drop	Air Press	Air In	Water In	Air Out	CO <sub>2</sub> In	CO <sub>2</sub> Out
				FT/min	FT/min	PSI(a)	PSIG	PSI	PSI	PSI	PSI	PSI
1	11/4/02 17:02	5.68	451.5	4.80	0.08	66.88	67.92	63.50	386	245		
2	11/4/02 17:09	3.80	449.9	3.58	0.06	66.67	67.68	63.44	386	247		
3	11/4/02 17:16	1.98	449.9	3.10	0.06	66.12	67.42	63.36	386	251		
4	11/4/02 17:23	0.72	450.9	2.93	0.05	65.79	67.12	63.15	386	255		

RESULTS

run	K <sub>DeA</sub>	NTU <sub>og</sub>	NTU <sub>dg</sub>	K <sub>G</sub>	Effective Area	Effective Area	Fractional Area	HYDRAULIC CALCULATIONS		
								water velocity	head	pressure drop
1	0.226	0.456	21.574	2.92E-05	321.63	98.03	0.64	7.37	1.33	0.488
2	0.222	0.447	21.982	2.94E-05	312.05	95.11	0.62	4.94	1.33	0.364
3	0.213	0.429	22.897	2.92E-05	301.96	92.04	0.60	2.57	1.33	0.315
4	0.206	0.416	23.630	2.79E-05	306.30	93.36	0.61	0.93	1.33	0.298

MASS TRANSFER CALCULATIONS

Molar Concentration	Ionic Concentration			tonic Strength	Henry's Law Constant	Viscosity	Diffusivity	Rate Constant	$\frac{Fq}{\mu_{air, m}}$
	Na	OH	HCO <sub>3</sub> <sup>-</sup>	CO <sub>2</sub>					
0.0770	0.08	0.0770	0.0000	0.0000	0.0770	30.2527	0.9394	1.7E-09	5.610
0.0750	0.08	0.0750	0.0020	0.0020	0.0800	29.4118	0.9386	1.73E-09	5.751
0.0750	0.08	0.0750	0.0020	0.0020	0.0800	29.4118	0.9386	1.73E-09	5.686
0.0700	0.08	0.0700	0.0070	0.0070	0.0875	29.4118	0.9366	1.72E-09	5.614

**APPENDIX A.4.4. Mass Transfer Data for the Fractal II Distributor (40 pts/ft<sup>2</sup>).  $\Delta P/Z_p = 0.75$  in H<sub>2</sub>O/ft.**

The Separations Research Program

packed height	1.18	inches	Packing:	Montz B1-500
f-factor	1.31	( $\frac{P_f}{P_a}$ ) $\left(\frac{V_f}{V_a}\right)^{0.5}$		
C <sub>ave</sub>	0.0480	N		
Tank Volume	300.00	gallons		
H <sub>w</sub>	0.034	g/mole/L-atm		
surface area/volume *	500.000	m <sup>2</sup> /m <sup>3</sup>		

\* approximate

**PROCESS DATA**

	Water Flow Ft <sup>3</sup> /min	Air Flow Ft <sup>3</sup> /min	Pressure Drop PSI <sub>1</sub> - <sub>2</sub>	Air Press PSI <sub>0</sub>	Air In T <sub>0</sub> , °F	Water In T <sub>0</sub> , °F	Air Out T <sub>0</sub> , °F	CO <sub>2</sub> Out
run #	time	KPHI	(ACFM)	(in H <sub>2</sub> O)	(PSIG)	(F)	(F)	ppm
1	11/4/02 17:56	15.36	292.5	7.65	0.12	65.54	62.18	180
2	11/4/02 18:05	11.456	351.56	7.72	0.12	67.47	62.14	385
3	11/4/02 18:16	7.71	448.4	7.80	0.13	69.73	66.06	210
4	11/4/02 18:26	3.85	543.0	7.84	0.14	73.12	62.41	385
5	11/4/02 18:34	1.99	585.7	7.66	0.14	74.92	65.84	244

**RESULTS**

run	K <sub>0,A</sub> S <sub>1</sub>	NTU <sub>0,A</sub>	NTU <sub>0,C</sub>	K <sub>0,C</sub>	Effective Area in <sup>2</sup> /in <sup>2</sup>	Effective Area ft <sup>2</sup> /ft <sup>2</sup>	Fractional area 1/Φ	
1	0.244	0.758	12.966	2.67E-05	380.08	115.85	0.76	
2	0.235	0.606	16.223	2.68E-05	362.86	110.60	0.73	
3	0.226	0.458	21.489	2.67E-05	351.28	107.07	0.70	
4	0.208	0.348	28.281	2.64E-05	327.06	99.69	0.65	
5	0.199	0.308	31.886	2.65E-05	311.14	94.84	0.62	

**HYDRAULIC CALCULATIONS**

	water velocity in/min	Reynolds number	friction factor $f_{\text{D}}$	pressure drop psi/in <sup>2</sup>
			$(f_D)_{\text{D}}$	$(f_D)_{\text{D}}$
1	19.93	0.78	0.87	0.78
2	14.87	0.85	1.04	0.785
3	10.00	0.93	1.32	0.793
4	4.99	1.60	0.797	
5	2.58	1.72	0.779	

**MASS TRANSFER CALCULATIONS**

Molar Concentration	Na <sup>+</sup>	OH <sup>-</sup>	HCO <sub>3</sub> <sup>-</sup>	CO <sub>2</sub>	Ionic Strength	Henry's Law Constant	Viscosity	Diffusivity	Rate Constant	$\frac{f_{\text{D}}}{f_{\text{D}} + f_{\text{L}}}$
N	0.0700	0.07	0.0700	0.0000	0.0700	30.1753	0.9366	1.70E-09	5.3445	0.04153
0.0680	0.07	0.0680	0.0020	0.0000	0.0730	29.4118	0.9357	1.70E-09	5.406	0.04153
0.0680	0.07	0.0680	0.0020	0.0000	0.0730	29.4118	0.9357	1.69E-09	5.362	0.04153
0.0670	0.07	0.0670	0.0030	0.0000	0.0745	29.4118	0.9353	1.69E-09	5.325	0.04151
0.0680	0.07	0.0680	0.0020	0.0000	0.0730	29.4118	0.9357	1.68E-09	5.310	0.04150

### Appendix A.15. Determination of Effective Mass Transfer Area

The effective mass transfer area of the packing may be estimated using a reactive absorption system such as air/CO<sub>2</sub>/caustic. The method of calculation and example calculation are provided in this section.

The absorption system can be described using two-film theory:

$$\frac{1}{K_{og} a} = \frac{1}{k_g a} + \frac{H}{k_l a}$$

where the liquid phase mass transfer coefficient is corrected for the chemical reaction.

$$\frac{1}{K_{og} a} = \frac{1}{k_g a} + \frac{H}{\beta k_l^0 a}$$

where:       $\beta$       = enhancement factor  
 $k_l^0$       = physical mass transfer coefficient

The enhancement factor  $\beta$  depends on the Hatta number (Ha) and  $\phi$ , where:

$$Ha = \sqrt{\frac{D_{AL} C_B^0 k_r}{k_l^0}}$$

$$\phi = \sqrt{\frac{D_{AL}}{D_{BL}}} + \sqrt{\frac{D_{BL}}{D_{AL}}} \left( \frac{C_B}{b C_A^*} \right)$$

where:       $D_{AL}$       = diffusion coefficient of CO<sub>2</sub> into the caustic phase  
 $D_{BL}$       = diffusion coefficient of NaOH ions into the caustic phase  
 $C_B$       = concentration of NaOH ions in caustic phase  
 $C_A^*$       = equilibrium concentration of CO<sub>2</sub> in the caustic phase  
 $k_r$       = rate constant

Assuming the liquid diffusion coefficients are equivalent ( $D_{BL} \sim D_{AL}$ ), then  $\phi$  may be rewritten:

$$\phi \cong 1 + \left( \frac{C_B}{b C_A^*} \right)$$

$$C_A^* = P_{CO_2}/H_{CO_2}$$

In general,  $\phi$  is quite large and for large values of  $\phi > 100$ , the enhancement factor ( $\beta$ ) is equivalent to the Ha number.

$$\text{Therefore } \frac{k_l}{k_l^0} = \frac{\sqrt{D_{AL} C_B^0 k_r}}{k_l^0}$$

or

$$k_l = \sqrt{D_{AB} C_B k_r}$$

Therefore the overall gas phase volumetric coefficient,  $K_{og}a$ , may be rewritten:

$$\frac{1}{K_{og} a} = \frac{1}{k_g a} + \frac{H}{\sqrt{D_{AB} C_B k_r} a}$$

In general for low concentrations of sodium hydroxide ( $C_B$ ), the gas phase resistance can be neglected. As a result,

$$K_{og} a = \frac{a \sqrt{D_{AB} C_B k_r}}{H}$$

Therefore, the mass transfer area can be deduced from the experimentally derived Koga and values of the diffusion coefficient ( $D_{AB}$ ), sodium hydroxide concentration ( $C_B$ ) and the reaction rate constant ( $k_r$ ).

### CALCULATION STEPS:

#### Step 1: Solve for the NTU

$$NTU_{og} = \ln \left( \frac{Y_{CO_2,in}}{Y_{CO_2,out}} \right)$$

Where  $NTU_{OG}$  is the number of transfer units in the gas phase.  
 $Y_{CO_2,in}$  is the ambient  $CO_2$  concentration (ppm) in the inlet stream and  
 $Y_{CO_2,out}$  is the  $CO_2$  concentration (ppm) in the scrubbed outlet stream.

#### Step 2: Solve for the HTU

$$HTU_{og} = \frac{Z_p}{NTU_{og}}$$

Where  $HTU_{OG}$  is the height of a transfer unit (ft)  
 $Z_p$  is the height of the contacting bed

### Step 3: Solve for the $K_{og}a$

$$\overline{K_{og}a} = \frac{U_s}{HTU_{og}} = \frac{U_s}{(Z_p / NTU_{og})}$$

Where  $U_s$  is the superficial vapor velocity (ft/s)  
 $K_{og}a$  is the mass transfer/area combined term and it has units of  $s^{-1}$ .

### Step 4: Calculate the Ionic Strength

$$I = \frac{1}{2} \sum z_i^2 C_i$$

Sherwood, Pigford, and Wilke, 1975, *Mass Transfer*, McGraw-Hill, New York (p. 362).

Where  $z_i$  is the number of positive or negative charges on an ion having molarity  $C_i$ . The number positive or negative charges in this case is determined by the ions in the solution,  $\text{Na}^+$  and  $\text{OH}^-$ . The molarity has units of gmol/L.

### Step 5. Calculate the Henry's Law Constant

$$\log_{10} \frac{H'}{H_w} = -h_i I$$

Sherwood, Pigford, and Wilke, 1975, *Mass Transfer*, McGraw-Hill, New York (p. 365).

$$H' = \frac{1}{H_w}$$

Where  $I$  is the ionic strength and  $h = h_+ + h_- + h_g$  (these values come from Table 8.4 on page 365 in the above reference) and  $H_w$  is the Henry's law coefficient for water.

The Henry's law coefficient is related to the value in water by this empirical equation.

### Step 6. Determine the Diffusivity:

$$D_{CO_2} = \frac{RT}{F^2} \cdot \frac{\frac{1}{n_+} + \frac{1}{n_-}}{\frac{1}{\lambda_+^0} + \frac{1}{\lambda_-^0}}$$

Sherwood, Pigford, and Wilke, 1975, *Mass Transfer*, McGraw-Hill, New York (p. 35).

Where  $R$  is the universal gas constant (8.315 J/K-gmol),  
 $T$  is the absolute temperature (K),  
 $F$  = Faraday = 96,488 C/g equiv  
 $\lambda_+^0, \lambda_-^0$  = limiting (zero concentration) ionic conductances at  $T$ , of cation and anion, respectively, (amp)/(cm<sup>2</sup>)(V/cm)(g equiv/cm<sup>3</sup>)  
 $n_+, n_-$  = valences of cation and anion, respectively

### Step 7. Calculate the Rate Constant:

$$\log_{10} k_r = 13.635 - \frac{2895}{T}$$

Sherwood, Pigford, and Wilke, 1975, *Mass Transfer*, McGraw-Hill, New York (p. 363).

Where  $k$  is the second order rate constant for the reaction of  $\text{CO}_2$  with hydroxyl ion in aqueous solutions and has units of L/(gmol·sec)  
 $T$  is the temperature in K

**Step 8. Calculate the effective area:**

$$K_{OG}a = \frac{a\sqrt{kD_{CO_2}C_{OH}}}{H}$$

Where a is the effective packing surface area  
 k is the rate constant, L/(gmol·sec). [step 7]  
 $D_{CO_2}$  is the Diffusivity of  $CO_2$  [step 6]  
 $C_{OH}$  is the concentration of  $OH^-$  ions remaining in the solution (after accounting for the amount consumed in the reaction), gmol/L  
 H is the Henry's law coefficient [step 5]

**EXAMPLE CALCULATION**

**BASES:**

Packed height, z	120	inches
Column diameter (i.d.)	16.81	inches
Molar Concentration	0.1	N NaOH
Conversion	5	%
Liquid rate	15,000	lb/hr
Air rate	180	acf m
$CO_2$ , ambient	360	ppm
$CO_2$ , process out	160	ppm
Pressure drop, $\Delta P$	3.0	in $H_2O$
$T_{air, in}$	100	°F
$T_{air, out}$	90	°F
$T_{water}$	80	°F
Henry's Law Constant (water), $H_w$	0.034	gmole/L·atm
$f_{Na^+}$	0.091	
$f_{OH^-}$	0.066	
$f_{(HCO_3^- & CO_3^{2-})}$	0.021	
$f_{CO_2}$	-0.019	
reaction	$2NaOH + CO_2 \rightarrow Na_2CO_3 + H_2O$	

**SOLUTION:**

**Step 1: Solve for the NTU**

$$NTU_{og} = \ln\left(\frac{360 \text{ ppm}}{160 \text{ ppm}}\right) = 0.811$$

**Step 2: Solve for the HTU**

$$HTU_{og} = \frac{120 \text{ in} \left(\frac{1 \text{ ft}}{12 \text{ in}}\right)}{0.811} = 12.33 \text{ ft}$$

Step 3: Solve for the  $K_{og}$

$$\overline{K_{og}} a = \frac{180 \frac{ft^3}{min} \left( \frac{1 min}{60 s} \right) \left( \frac{1}{1.54 ft^2} \right)}{12.33 ft} = 0.157 s^{-1}$$

Step 4: Calculate the Ionic Strength

$$I = \frac{1}{2} [(1^2)(0.100) + (1^2)(0.095) + (2^2)(0.005)] = 0.1075$$

The concentrations listed are for the ions:  $\text{Na}^+$ ,  $\text{OH}^-$ , and  $\text{CO}_3^{2-}$ , respectively (see formula above). This is based on the assumption that the solution was initially 0.1 N NaOH and that 5% of the available  $\text{OH}^-$  have reacted to form  $\text{Na}_2\text{CO}_3$ .

Step 5. Calculate the Henry's Law Constant (with temperature correction)

$$\sum h_i = 0.91 + 0.66 + 0.21 - 0.19 = 1.59$$

$$\log_{10} \frac{H'}{0.034 \frac{gmol - sec}{L}} = -(1.59)(0.1075)$$

$$H = \frac{1}{H'} = \frac{1}{0.0327 \frac{gmol}{L \cdot atm}} = 30.6 \frac{L \cdot atm}{gmol}$$

Step 6. Determine the Diffusivity:

$$D_{\text{CO}_2} = \frac{8.315 \frac{J}{K \cdot gmol} \cdot 300 K}{\left( 96,488 \frac{C}{g_{equiv}} \right)^2} \cdot \frac{\frac{1}{1} + \frac{1}{1}}{\frac{1}{50.1 \frac{amp}{cm^2} \left( \frac{V}{cm} \right) \left( \frac{g_{equiv}}{cm^3} \right)} + \frac{1}{197.6 \frac{amp}{cm^2} \left( \frac{V}{cm} \right) \left( \frac{g_{equiv}}{cm^3} \right)}} \cdot \frac{1 m^2}{100^2 cm^2} = 2.14 \times 10^{-9} \frac{m^2}{s}$$

Step 7. Calculate the Rate Constant:

$$\log_{10} k = 13.635 - \frac{2895}{T}$$

$$\log_{10} k = 13.635 - \frac{2895}{(460 + 80)/1.8}$$

$$k = 10^{13.635 - \left( \frac{2895}{300} \right)} = 9,660 \frac{L}{gmol \cdot s}$$

**Step 8. Calculate the effective area:**

$$K_{OG} = \frac{\sqrt{k D_{CO_2} C_{OH}}}{H}$$

Because the value for  $K_{OG}$  has been determined from empirical data, it is possible to calculate the effective area.

$$K_{OG} = \frac{\sqrt{9,660 \frac{L}{gmol \cdot s} \cdot 2.14E-9 \frac{m^2}{s} \cdot 0.095 \frac{gmol OH^-}{L}}}{30.6 \frac{L \cdot atm}{gmol}} = 4.57E-5 \frac{m}{s} \cdot \frac{gmol}{L \cdot atm}$$

$$a = \frac{\rho_g \cdot K_{OG} a}{K_{OG}} = \frac{0.04 \frac{gmol}{m^3} \cdot 0.157 s^{-1}}{4.57E-5 \frac{m}{s} \cdot \frac{gmol}{L \cdot atm}} = 137 \frac{m^2}{m^3}$$